

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3225-0245:111

CATEGORY: Fire Dampers

LISTEE: Ruskin Mfg., 3900 Dr. Greaves Road, Grandview, MO 64030
Contact: Robert Van Becelaere (816) 761-7476

DESIGN: Model FSD36-C, fire rated damper. Minimum size 12" wide X 6" high, maximum size 24" wide X 24" high. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, reference to "horizontal installation only" and UL label.

APPROVAL: Listed as 1-hour fire rated damper for horizontal installation only. Refer to category 3230 for listed leakage dampers.

01-12-95



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

MAY 14, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager